



Internet: www.awqc.com.au

Email: producttesting@awqc.com.au

FINAL REPORT

Report ID : 369234

Report Information

Submitting Organisation : 00109376 : HANSEN PRODUCTS (NZ) LIMITED

Account : 130354 : Hansen Products (NZ) Limited - AS/NZS 4020 Testing

AWQC Reference : 130354-2023-CSR-3 : Prod Test: Hansen Easy Fit Compression fittings (MD)

Project Reference : PT-5232

Product Designation : Hansen Easy Fit Compression Fittings (HMDC16 - 16mm Representative Model)

Composition of Product : Polypropylene (see attachment).

Product Manufacturer : Hansen Products (NZ) Ltd, Whangarei, NEW ZEALAND.

Use of Product : In-Line/Water Pipe Fitting.

Sample Selection: As provided by the submitting organisation.

Testing Requested : **AS/NZS 4020:2018 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER**

Product Type : Composite

Samples : Samples were prepared and controlled as described in Appendix A of AS/NZS 4020:2018 (Incorporating Amendment No.1)

Extracts : Extracts were prepared as described in Appendix/Clause C, D, E, F, G, H, 6.8.

Project Completion Date : 31-Aug-2023

Project Comment : Samples received 12-May-2023, testing commenced 15-May-2023. Product range to include 16mm to 110mm sizes.

PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL

THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING TO AS/NZS 4020:2018. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



FINAL REPORT

Report ID : 369234

Summary of Results

APPENDIX/CLAUSE	RESULTS
C – Taste	Passed when tested in-the-product with a scaling factor of 0.01 applied.
D – Appearance	Passed when tested in-the-product with a scaling factor of 0.01 applied.
E – Growth of Aquatic Micro-organisms	Passed when tested at the end-use exposure.
F – Cytotoxic Activity	Passed when tested in-the-product with a scaling factor of 0.01 applied.
G – Mutagenic Activity	Passed when tested in-the-product with a scaling factor of 0.01 applied.
H – Metals	Passed when tested in-the-product with a scaling factor of 0.01 applied.
6.8 – Organic Compounds	Passed when tested in-the-product with a scaling factor of 0.01 applied.

Test Methods

Test(s) in Appendix	AWQC Test Method	NATA Accredited
C	T0320-01	Y
D	TO029-01 & TO018-01	Y
E	TO014-03	Y
F	TM-001	Y
G	TM-002	Y
H	TIC-006	Y

Organic Test Methods

Test(s) in Clause	Test Method	NATA Accredited
Clause 6.8	TMZ-M36	Y
	EP239	Y
	EP132-LL	Y
	EP075C	Y
	EP075ASIM	Y



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



FINAL REPORT

Report ID : 369234

Laboratory Information

Laboratory	NATA accreditation ID
Product Testing	1115
Australian Laboratory Services Pty Ltd - New South Wales	825,992
Inorganic Chemistry - Physical	1115
Protozoology	1115
Organic Chemistry	1115
Inorganic Chemistry - Metals	1115
Inorganic Chemistry - Waste Water	1115

Summary Comment : The AWQC is not NATA accredited for the following tests: Nitrosamines, Phenols, Phthalate Esters and Polycyclic Aromatic Hydrocarbons. These tests are subcontracted to testing facilities that are NATA accredited for these analyses.



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>